

LCD28

Thank you for having chosen an LAE electronic product. Before installing the instrument, please read this instruction booklet carefully in order to ensure safe installation and optimum performance.

1. INSTALLATION

1.1 LCD28, size 105x90x55 mm (WxHxD), must be fitted to a DIN rail in such a position so as to prevent debris and moisture infiltration which may cause serious damage and compromise safety.

1.2 The instrument should work with room temperatures between -10°C.. +50°C and relative humidity between 15%.. 80% inclusive. Supply voltage, switched powers and connection set-up should scrupulously comply with the indications given on the container. To reduce the effects of electromagnetic disturbance, keep the flat connecting cable, the sensor and signal cables well separate from the power wires.

1.3 The display unit LCD16 is secured to the panel by means of the two springs on the side of the box. The unit is mounted on the panel through a 29x71 mm opening, exert a moderate pressure so as to get the LCD16 to align flush to the panel surface. The main unit LCD28 and the display unit LCD16 are connected to each other by means of the flat cable supplied in the package.

1.4 The sensor T1 measures the air temperature and activates in the thermostat control cycle; it should be placed inside the appliance in a point that truly represents the temperature of the stored product. The sensor T2 measures the evaporator temperature and should be placed where there is the maximum formation of frost. If fitted, sensor T3 should be located between the condenser fins, close to the condenser outlet.

CAUTION: should the relays have to switch a heavy load frequently, it is advisable to contact the manufacturer for indications on the lifetime of the contacts.



Whenever products must be kept within very severe specifications or the products have considerable value, the use of a second instrument is recommended, which activates upon or warns of any malfunction.

2. OPERATING MODES

Upon switching on, just the central line (autotest) appears on the display for approximately three seconds and the subsequent indications depend on the operating status of the controller. TABLE 1 gives the indications associated with the various states, whereas the symbols appearing below are explained in TABLE 2.






STANDBY	NORMAL	INFO MENU	INFO DATA	SETUP MENU	PARAMETER VALUE
OFF Not Operating	-19 Product Temper. (sim.)	T1 Air temperature	→ -20	SCL Display scale	→ 1°C
	DEF Defrost	T2 Evaporator temperature	→ -25	SPL Minimum setpoint	→ -25
	REC Recovery after defrost	---	→ ---	SPH Maximum setpoint	→ -18
	HI High temperature alarm	TLO Min. stored temperature	→ -19	---	→ ---
	---	CND Condenser clean cycle	→ 15	---	→ ---
	E1 Faulty T1 probe	LOC Locked keypad	→ NO	---	→ ---



TABLE 1



2.1 STANDBY. If button  is pressed for 3 seconds, it allows the LCD15 to be put on a standby, or to resume output control (with parameter **SB**=YES only). An  indication on the display shows that the outputs are off permanently.



2.2 NORMAL. During normal operation, the display shows the temperature measured by probe T1, presented in the most appropriate manner. Parameter **SCL** may be adjusted in °C with auto-range (SCL=1°C), in °C with 1° fixed resolution (SCL=2°C) or in Fahrenheit









(SCL=°F). The measured temperature may be corrected with a fixed offset by assigning a value other than 0 to the parameter **OS1**. Additionally, prior to display, the temperature is treated by an algorithm that allows the simulation of a thermal mass directly proportional to the **SIM** value. The result is a reduction in the fluctuation of the displayed value.




2.3 INFO MENU. Pressing the button  and releasing it immediately activates the information selection menu. From this menu you can display the instantaneous temperatures T1, T2 and T3; the maximum (THI) and minimum (TLO) stored temperature; the total operating time of the condenser since its last cleaning (CND) and the keypad status (LOC). The information to be displayed can be selected sequentially, by pressing  repeatedly or quickly via the buttons  and  to scroll through the menu. Exit from the info menu is by pressing button  or automatic after 6 seconds of not using the keypad.

In the INFO operating mode it's also possible to reset the recordings THI and TLO and the hour counter CND by pressing buttons  +  simultaneously while the value is displayed.













2.4 KEYPAD LOCK. The keypad lock avoids undesired, potentially dangerous operations, which might be attempted when the controllers is operating in a public place. In the INFO mode, through the buttons  and  it's possible to assign YES or NO to the parameter LOC. With LOC=YES all keypad commands are inhibited. To resume normal operation of keypad, adjust setting so that LOC=NO.

2.5 DEFROSTING. By assigning a value greater than 0 to the parameter **DDY**, during defrost the indication  is displayed instead of the temperature. In this case, after defrost and for the time programmed in DDY, the display indication  shows that the normal thermostatic cycle is being resumed.

2.6 ALARM. An anomaly in the operation is displayed through the lighting up of an abbreviation showing its cause: / high/low alarm temperature in the cabinet,  door open,  condenser high temperature,  periodic condenser cleaning, // fault of probe T1 / T2 / T3.

2.7 SETUP. The setup is accessed by pressing the buttons  +  +  in succession and keeping them pressed simultaneously for 5 seconds. The available parameters appear in TABLE 2 as shown below.

3. CONFIGURATION

The controller is configured for the system to be controlled by programming the operating parameters, that is, through the setup (see par. 2.7). The instrument is dispatched with a general setup and the suitability of the parameters must therefore be checked before use. In SETUP, press button  to pass from one parameter to the next, and press button  to go back. To display the value of a parameter press , to modify it press buttons  +  or  +  simultaneously. Exit from the setup is by pressing button  or automatic after 30 seconds of not using the keypad. The setpoint **SP (IISP)** can be displayed and programmed even during normal operation of the controller, by pressing button  +  or  + . The range will always remain within the limits **SPL** and **SPH (IISL and IISH)**.


SCL	1°C/2°C/°F	Readout scale	AHT	0.. 75 [°]	Condenser alarm temperature
SPL	-40.. SPH [°]	Minimum temperature set point	AHM	NON/ALR/STP	Condenser high temperature alarm operation
SPH	SPL.. +40 [°]	Maximum temperature set point	ACC	0.. 52 [weeks]	Periodic condenser cleaning
SP	SPL.. SPH [°]	Effective temperature set point	HDS	1.. 5	Sensitivity function eco/heavy duty
HYS	+0.1.. +10.0 [°]	Thermostat hysteresis	IISM	NON/MAN/HDD/DI2	2nd set switching mode
CRT	0.. 30 [min]	Compressor rest time	IISL	-40.. IISH [°]	Minimum 2nd temperature set
CDC	0.. 10	Compressor regulation with sensor T1 failure	IISH	IISL.. +40 [°]	Maximum 2nd temperature set
CSD	0.. 30 [min]	Compressor stop delay from door opening	IISP	IISL.. IISH [°]	Effective 2nd temperature set
DFR	0.. 24	Defrosting frequency /24h	IIHY	+0.1.. +10.0 [°]	Hysteresis of 2nd temperature set
DLI	-40.. +40 [°]	Defrost end temperature	IIDF	0.. 24	Defrosting frequency /24h in mode 2
DTO	1.. 120 [min]	Maximum defrosting duration	IIFT	YES/NO	Evaporator fan timed control in mode 2
DTY	OFF/ELE/GAS	Defrost type	SB	YES/NO	Button  enabling
DRN	0.. 30 [min]	Drain down time	DS	YES/NO	Door switch enabling
DDY	0.. 60 [min]	Defrosting display control	OAU	NON/O-1/ALR	Control of AUX output
FID	YES/NO	Fans active during defrost	OS1	-12.. +12 [°]	Probe T1 offset
FDD	-40.. +40 [°]	Fan re-start delay temperature	T2	YES/NO	Probe T2 enabling
FTC	YES/NO	Evaporator fan timed control	OS2	-12.. +12 [°]	Probe T2 offset
FPC	0.. 3	Evaporator fans ON/OFF ratio coefficient	T3	YES/NO	Probe T3 enabling
ATL	-12.. 0 [°]	Low alarm differential	OS3	-12.. +12 [°]	Probe T3 offset
ATH	0.. +12 [°]	High alarm differential	TLD	1.. 30 [min]	Delay for min./max. temperature storage
ATD	0.. 120 [min]	Alarm temperature delay	SIM	0.. 100	Display slowdown
ADO	0.. 30 [min]	Door alarm delay	ADR	1.. 255	Peripheral address

TABLE 2

CAUTION: upon changing the display scale SCL, it is **ESSENTIAL** to reconfigure the parameters related to the absolute (SPL, SPH, SP, etc.) and differential (HYS, ATL, ATH, etc.) temperatures.

4. THERMOSTAT CONTROL

4.1 Thermostat control is based on comparing the temperature T1, the set point ***SP** and the hysteresis ***HYS**.

Example: SP= 2.0; HYS= 1.5, compressor Off with T1= +2.0° and On with T1= +3.5° (2+1.5).

The compressor only switches On again if the Off time period determined by **CRT** since the previous switchover has elapsed. Whenever a very small hysteresis HYS must be maintained, it is advised that a suitable value for CRT is selected in order to reduce the number of starts per hour.

4.2 If sensor T1 fails, the output is controlled by parameter **CDC** as a proportion of a 10 minute operating cycle.

Example: CDC=06, 6 minutes On, 4 minutes Off.

4.3 If door switch input control has been enabled (**DS=YES**), parameter **CSD** determines the delay between when the door is opened and the compressor stopping.

* Actual setpoint and hysteresis depend on the selection **I/II**: in mode **I**, the reference parameters are **SP** and **HYS** while in mode **II**, **IISP** and **IIHY**.

5. DEFROSTING

5.1 Defrosting starts automatically when necessary time has elapsed to obtain the defrosting frequency set with ***DFR**. For example, with DFR=4 there will be 4 defrostings per 24 hours, so defrosting occurs once every 6 hours.

The internal timer is set to zero when power is applied to the controller and at each subsequent defrost start. When the controller is put on a standby, the accumulated time count is "frozen" (is not incremented).

Defrosting may also be induced manually by keeping the button  pressed for 2 seconds.

During a High Pressure alarm (see par. 7.3), defrost is suspended.

5.2 Once defrost has started, the outputs are controlled according to parameter **DTY** as per the following table:

DTY	DEFROST	COMPRESSOR
OFF	Off	Off
ELE	On	Off
GAS	On	On

TABLE 3

5.3 Defrost lasts for the time **DTO** but, if the evaporator probe has been enabled (T2=YES) and temperature **DLI** is achieved before this time elapses, defrost will be terminated in advance.

If parameter **DRN** is greater than 0, before cooling starts all outputs will remain off for the time assigned to DRN. This phase, called drain down, will allow a complete ice melting and the drain of the resulting water.

* The actual defrost frequency depends on the selection **I/II**: in mode **I**, the reference parameter is **DFR** while in mode **II** it's **IIDF**.

6. EVAPORATOR FANS

6.1 During thermostatic control, the evaporator fans are controlled by parameter ***FTC** and **FPC**. With FTC=NO, the fans operate continuously regardless of the FPC value set. Alternatively, when FTC=YES the evaporator fans will operate in conjunction with the compressor (i.e. when the compressor runs the fans will run), but dependant upon the FPC value set they will On/Off cycle after the compressor has stopped. With FPC set between 1 to 3, you will obtain On/Off ratios of respectively, 33%, 50% and 60% with fixed 60 second off times. Therefore, once the compressor has stopped, with FPC=1 (33%) the fans will run for 30 seconds and stay off for 60 seconds. If FPC=2 (50%) the fans will run for 60 seconds and remain off for 60 seconds; with FPC=3 (60%) the fans will run for 90 seconds and stay switched off for 60 seconds. This cycle pattern will continue until the compressor starts again. With FPC=0, the fans will follow the compressor cycle only.

This fan control function aims at recovering the maximum cooling effect available at the evaporator as well as greatly reducing unwanted heat generated by the evaporator fan motors, so increasing the energy efficiency. Cycling the fans also avoids air stratification, and allowing the temperature measured by probe "T1" to be updated, and thus accurate. If the temperature to be maintained is above freezing then the maximum humidity is maintained in the chilled environment.

6.2 If the LCD28 is connected to a door switch and door switch control is enabled (**DS=YES**), during thermostatic control if the door is opened, the fans will be stopped immediately.

6.3 During defrost, the fans are controlled by parameter **FID**; with FID=YES the fans remain on all through defrosting. With FID=NO, the fans will be stopped and will only re-start when the conditions in paragraph 6.4 have been met.

6.4 After defrosting, if probe T2 is active (T2=YES), temperature **FDD** provides evaporator fan re-start. So the evaporator fans will not run until the evaporator has a temperature lower than FDD. If such condition doesn't occur within 4 minutes following defrost termination,

the fans will however be switched on again.



* The way the fans will be controlled depends on the selection **I/II**: in mode **I** they work according to **FTC**, while in mode **II** the fans work according to **IIFT**.

7. ALARMS


With LCD28, correct operation of the refrigerator and thermostat may be monitored by a wide range of functional and diagnostics alarms, individually selectable by means of the relevant parameters. The alarm warnings are given on the display through explicit indications (see following par.), the auxiliary relay contacts open (if present in model and if OAU=ALR) and intermittent buzzer sounding. During an alarm, by pressing any button, the buzzer is muted. Then, if the alarm persists, the buzzer will be periodically switched on for 20 seconds every 60 minutes, until the alarm ends (the display indications remain on all the time). The repeated acoustic warning applies to all alarms with the exception of the condenser cleaning alarm. Operation of the various elements is given in detail below.


7.1 The parameters **ATL** and **ATH** define two differential temperatures that, referred to the set point, determine the temperature alarm thresholds. ATL establishes the alarm differential for temperatures below set point, ATH the alarm differential for temperatures above set point + hysteresis. Putting one or both differentials to 0 cuts out the corresponding alarm.

Example: SP= -20, HYS= 2.0, ATL= -5.0, ATH= 05.0; the alarm thresholds are set at -25°(-20-5) and -13° (-20+2+5).

The alarm warning may be immediate or delayed by the time **ATD** whenever this is greater than 0. The indication  for high temperature and  for low temperature alarm blinks on the display. The alarm indication remains stored in the display, even when the alarm is over, until you acknowledge the alarm manually by pressing any button.

The high temperature alarm is bypassed during defrosting.

7.2 If a suitable door switch has been connected to detect the door status and door switch input control has been enabled (DS=YES), the door open alarm function is enabled. In this way, if the door remains open the controller will react after the time delay set with **ADO** by displaying the alarm source through the indication .




7.3 To monitor the condenser temperature to avoid gas pressure from getting too high, it's necessary to secure probe T3 to the condenser firmly (see 1.4) and enable condenser probe control (T3=YES). Parameter **AHT** determines the condenser temperature alarm threshold and parameter **AHM** determines the reaction following the temperature rising over AHT. With AHM=ALR the only reaction will be the buzzer sounding,  being displayed and the alarm relay switched on. Alternatively, with AHM=STP, besides the alarm indication the compressor will be stopped immediately and defrosts suspended.

With AHM=NON, all functions related to the High Pressure alarm are inhibited.

7.4 Assigning a value greater than 0 to the parameter **ACC** enables the indication for periodic cleaning of the condenser. Subsequently, when the count of compressor hours of operation reaches the equivalent in weeks set with ACC, an indication for cleaning appears on the display.

*Example: with ACC=16 there is a warning once every $16 \times 7(\text{weeks}) \times 24(\text{hours}) = 2688$ hours of **compressor operation**, so, assuming for this an operation with 5 minutes On and 5 minutes Off - after approx. 32 weeks.*

In order to clear the time counter, follow the prescribed procedure in paragraph 2.3.

7.5 Upon failure of probe T1 or, if enabled, probes T2 and T3, probe failure is signalled with the blinking indication  or  or  respectively.

8. TEMPERATURE STORAGE

The LCD28 features a system for permanent storage of the minimum and maximum temperature logged during operation. This system is a valid help to achieve compliance with the HACCP directive in its part relating to a correct preservation of foodstuffs. Temperature is measured by probe T1 which should therefore be placed in a point where the temperature of the preserved product may always be measured correctly. The logging is however subject to some simple rules that filter the data and give a rational interpretation. The logging is suspended during the periods in which the refrigerator is put on a standby and during defrostings and, during the normal operation (thermostatic control), it's "slowed down" through the parameter **TLD**. This parameter defines the time during which the measured temperature must permanently exceed the current value before the logging is performed. In this way, it will be possible to avoid idle loggings that don't reflect the actual product temperature, for example, the door being left open, the temperature recovery after a defrost or other temporary short term temperature huntings.

It is suggested that a reasonably long TLD time is programmed, for instance 5-15 minutes, you then put the product into the refrigerator and start a new logging cycle by clearing previous values (see par. 2.3). It will now suffice that at regular intervals, in the INFO menu you check the minimum and maximum logged values in order to know if the product has been kept within the required temperature limits.

9. AUXILIARY FUNCTIONS

9.1 In addition to the basic functions described above, the LCD28 offers an innovative feature to enhance the performance of the refrigerator. Infact, you can select the control parameters between two different pre-programmed groups, in order for the fundamental control parameters to be adapted quickly to changing needs such as, for example: High/Low Temperature range change, stored product

change (meat, fish, vegetables ...), maximum cooling capacity or energy saving. The parameters switched over in mode I and II are: **SPL, SPH, SP, HYS, DFR, FTC** and **IISL, IISH, IISP, IIHY, IIDF, IIFT**.

With the parameter **IISM** you select if the changeover from Group I to Group II is made manually via the button **III** (IISM=MAN), or automatically when heavy duty operation is detected (IISM=HDD), or when the auxiliary input is activated (IISM=DI2), or inhibited (IISM=NON). The activation of Group II is signalled by the lighting up of the relevant LED on the controller display.

9.2 The automatic detection of "heavy duty operation" allows the control parameters to be modified in response to the specific temporary needs of the refrigerator, such as: warm food being put into the cabinet, door being opened frequently etc. Control sensitivity to switch over from Group I to Group II is determined by parameter **HDS** (1=minimum, 5=maximum). An example of how to use such function is reported in the following table:

PARAMETER	GROUP I	GROUP II
Setpoint	SP= -18	IISP= -21
Hysteresis	HYS= 2.0	IIHY= 3.0
Defrost frequency	DFR= 3	IIDF= 1.. 0
intermit. fans	FTC= YES	IIFT= NO

If we apply the above example to a refrigerator in a restaurant kitchen the controller will use the parameters of Group I during the closing times of the kitchen, when the need for cooling is minimum, therefore we can consider this as a "normal" operation condition. Group I "economy control" parameters will ensure both an optimum foodstuff preservation and considerable energy saving. Alternatively, during very busy periods (door being opened continuously to take out or load food), the controller will automatically select Group II to try and maintain the average product temperature within correct values (lower setpoint), limit compressor wear by reducing the number of starts (higher hysteresis), avoid long defrost pauses which will worsen the preservation condition (lower defrost frequency or no defrosts at all), increase product cooling speed by keeping ventilation always active (FTC=NO). When the heavy duty period is over, the controller will automatically resort back to Group I.

NOTE: To make the automatic detection IISM=HDD work better, it is suggested that the value of hysteresis is not set too narrow (less than 2°K) or the value of CRT is not set too high (longer than 2 minutes)

9.3 The operation of the auxiliary output (if this is present depending on the model), is controlled by means of parameter **OAU**. With OAU=0-1 the relay contacts follow the on/off status of controller (standby=OFF); with OAU=ALR the relay contacts are closed during normal operation and open when an alarm condition occurs (reverse operation); with OAU=NON the contacts remain open constantly.

9.4 The controller is provided with a serial port for connection to a PC or a programmer. In the first case it is important to assign to the parameter **ADR** a different value for each linked unit (peripheral address); with automatic programming, ADR should remain on 1.

WARRANTY

LAE electronic SPA guarantees its products against defects due to faulty materials or workmanship for one (1) year from the date of manufacture shown on the container. The Company shall only replace products which are shown to be defective to the satisfaction of its own technical services. The Company shall not be under any liability and gives no warranty in the event of defects due to exceptional conditions of use, misuse or tampering.

LAE electronic does not accept units back unless LAE electronic has previously given its allowance or request.

WIRING DIAGRAM

